

OFFICE OF THE EXECUTIVE ENGINEER  
EASTERN DIVISION No.12  
D.D.A., GEETA COLONY, DELHI -31

CERTIFICATE OF DRINKING WATER

It is certified that DDA has granted permission for bulk potable water connection Somerville School at Vasundhara Enclave Delhi-110096 vide No. F.1(92)/AE.IV/ED.12/DDA/58 dt. 22.4.2008. D.D.A. is supplying drinking water to school from Dallupura U.G.R. which is drawing water from Bhagirathi treatment plant of D.J.B.

23.6.2009

*[Signature]*  
Executive Engineer,  
E.D.-12/DDA

*[Signature]*  
The Manager  
Somerville School  
Vasundhara Enclave  
Delhi-110 096



### Test Report

Quality Standard	Parameters as desired	
Issued to	-	Somerville School, Vasundhara Enclave, New Delhi
Kind attn.	-	Mr.
Analysis no.	-	23052219

Nature of Sample	-	Water Sample marked RO-02
Sample received on	-	22 <sup>nd</sup> May 2023
Report Date	-	27 <sup>th</sup> May 2023
Analysis Dates	-	22 <sup>nd</sup> May 2023 to 27 <sup>th</sup> May 2023
Sample receipt	-	Picked by Lab
Sample Packing	-	Sterilized and Pet Bottles

	PARAMETER	UNIT	RESULT	TEST METHOD	LIMITS	
					Desired	Permissible (in absence of alternate source)
General	Color	Hazen	<b>05</b>	IS 3025 Part 4	05	25
	Odor	Unit Less	<b>Unobjectionable</b>	IS 3025 Part 5	Unobjectionable	Unobjectionable
	Taste	Unit Less	<b>Agreeable</b>	IS 3025 Part 6	Agreeable	Agreeable
Bacteria	Coliform	CFU/100ml	<b>Absent</b>	IS1622	Absent	Absent
	E.Coli	CFU/100ml	<b>Absent</b>	IS1622	Absent	Absent
Physical	pH	Unit Less	<b>6.67</b>	IS 3025 Part 11	6.5-8.5	No Relaxation
	Conductivity	microS at 25°C	<b>70</b>	IS 3025 Part 14	...	---
	Turbidity	NTU	<b>1.0</b>	IS 3025 Part 10	5	10
	Total Dissolved Solids	mg/l	<b>45</b>	IS 3025 Part 16	500	2000
Chemical	M. Alkalinity as CaCO <sub>3</sub>	mg/l	<b>14</b>	IS 3025 Part 23	200	600
	Total Hardness as CaCO <sub>3</sub>	mg/l	<b>5.9</b>	IS 3025 Part 21	300	600
	Chlorides as Cl	mg/l	<b>19.2</b>	IS 3025 Part 32	250	1000
	Total Iron as Fe	mg/l	<b>0.01</b>	IS 3025 Part 53	0.3	1.0
	Residual Free Chlorine	mg/l	<b>Nil</b>	IS 3025 Part 35	0.20	--

Remarks: The no. of parameters tested is 14 only. The report is issued subject to the terms & conditions as mentioned overleaf.  
Chemist Authorized Signatory

  
  
 Reviewed by Sign :   
 Designation : **Quality Analyst**

Issued by Sign :   
 Name : **Dilip Thakur**  
 Designation : **Technical Manager**

  
 The Manager  
 Somerville School  
 Vasundhara Enclave  
 Delhi-110 096



**QUALITY LAB** is a trademark and fully owned unit of Quality Analyst & Labs Pvt. Ltd.

Office : 382, Vardhman Charve Plaza-5, Plot No. 20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088

Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA

Exclusive representatives in India for Sens Aqua, Naeringshagen No. 7340. OPPDAL, Norway

Exclusive representatives in India for Femko Technical Control and Certification Ltd., Izmir, Turkey for CE Marking

**Test Report**

Quality Standard	Parameters as desired
Issued to	- Somerville School, Vasundhara Enclave, New Delhi
Kind attn.	- Mr.
Analysis no.	- 23052218

Nature of Sample	- Water Sample marked RO-01
Sample received on	- 22 <sup>nd</sup> May 2023
Report Date	- 27 <sup>th</sup> May 2023
Analysis Dates	- 22 <sup>nd</sup> May 2023 to 27 <sup>th</sup> May 2023
Sample receipt	- Picked by Lab
Sample Packing	- Sterilized and Pet Bottles

	PARAMETER	UNIT	RESULT	TEST METHOD	LIMITS	
					Desired	Permissible (in absence of alternate source)
General	Color	Hazen	<b>05</b>	IS 3025 Part 4	05	25
	Odor	Unit Less	<b>Unobjectionable</b>	IS 3025 Part 5	Unobjectionable	Unobjectionable
	Taste	Unit Less	<b>Agreeable</b>	IS 3025 Part 6	Agreeable	Agreeable
Bacteria	Coliform	CFU/100ml	<b>Absent</b>	IS1622	Absent	Absent
	E.Coli	CFU/100ml	<b>Absent</b>	IS1622	Absent	Absent
Physical	pH	Unit Less	<b>6.56</b>	IS 3025 Part 11	6.5-8.5	No Relaxation
	Conductivity	microS at 25*c	<b>45</b>	IS 3025 Part 14	---	---
	Turbidity	NTU	<b>1.0</b>	IS 3025 Part 10	5	10
	Total Dissolved Solids	mg/l	<b>26</b>	IS 3025 Part 16	500	2000
Chemical	M. Alkalinity as CaCO3	mg/l	<b>9.4</b>	IS 3025 Part 23	200	600
	Total Hardness as CaCO3	mg/l	<b>1.9</b>	IS 3025 Part 21	300	600
	Chlorides as Cl	mg/l	<b>9.5</b>	IS 3025 Part 32	250	1000
	Total Iron as Fe	mg/l	<b>0.01</b>	IS 3025 Part 53	0.3	1.0
	Residual Free Chlorine	mg/l	<b>Nil</b>	IS 3025 Part 35	0.20	--

Remarks: The no. of parameters tested is 14 only. The report is issued subject to the terms & conditions as mentioned overleaf.

Chemist

Authorized Signatory




Reviewed by Sign : *Dillip Thakur*  
Designation : **Quality Analyst**

Issued by Sign : *Dillip Thakur*  
Name : **Dillip Thakur**  
Designation : **Technical Manager**

*Somerville School*  
The Manager  
Somerville School  
Vasundhara Enclave  
Delhi-110 096



**QUALITY LAB** is a trademark and fully owned unit of Quality Analyst & Labs Pvt. Ltd.

Office : 382, Vardhman Charve Plaza-5, Plot No. 20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088

Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA

Exclusive representatives in India for Sens Aqua, Naeringshagen No. 7340. OPPDAL, Norway

Exclusive representatives in India for Femko Technical Control and Certification Ltd., Izmir, Turkey for CE Marking

**MUNICIPAL CORPORATION OF DELHI**  
PUBLIC HEALTH DEPARTMENT  
SHAHDARA (SOUTH) ZONE  
419 1<sup>st</sup> Floor, UDYOG SADAN  
PATPARGANJ INDUSTRIAL AREA DELHI-110092

No. : DHO/Shd.(S)/2024/D-899

Date:25.01.2024

**School Health Certificate**


1. Name of School	: Somerville School
2. Location of the School	: Vasundhara Enclave Delhi-96
3. No. of Staff	:267
4. No. of Rooms	: 94
5. No. of Students	:2377 (Boys-1297 & Girls-1080)
6. No. of Doors in each room	:Exist in each room
7. No. of Fans in each room	: Exist in each room
8. Desk/Chair	: Provided
9. Building Structure	:Pucca
10. Drinking Water	:DJB Supply
11. Electricity	:BSES
12. No. of Urinals for Boys	: 64
13. No. of W.C. for Boys	: 41
14. No. of W.C. for Girls	: 45


At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal  
Somerville School  
Vasundhara Enclave Delhi-96


  
Deputy Health Officer  
Shahdara (South) Zone  
DEPUTY HEALTH OFFICER  
MUNICIPAL CORPORATION OF DELHI  
SHAHDARA (SOUTH) ZONE

  
The Manager  
Somerville School  
Vasundhara Enclave  
Delhi-110 096